



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Cathy Ledden
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

3/29/2022

Phone: (609) 820-9312
Fax: (609) 561-6197

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/14/2022. The results are tabulated on the attached data pages for the following client designated project:

BOE Pb Requirement Shaner Elementary - Initial

The reference number for these samples is EMSL Order #012204009. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012204009
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 3/14/2022 10:00 AM

Project: **BOE Pb Requirement Shaner Elementary - Initial**

Analytical Results

Client Sample Description S-1-POE / Boiler Room **Collected:** 3/12/2022 8:00:00 AM **Lab ID:** 012204009-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 17:47

Client Sample Description S-3-SNK / Sink Left Kitchen 3 Well **Collected:** 3/12/2022 8:01:00 AM **Lab ID:** 012204009-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 17:52

Client Sample Description S-4-SNK / Sink Right Kitchen 3 Well **Collected:** 3/12/2022 8:02:00 AM **Lab ID:** 012204009-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.16	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 17:54

Client Sample Description S-7-WC / Room K20 Fountain **Collected:** 3/12/2022 8:03:00 AM **Lab ID:** 012204009-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 17:58

Client Sample Description S-8-WC / Room K19 Fountain **Collected:** 3/12/2022 8:04:00 AM **Lab ID:** 012204009-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012204009
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 3/14/2022 10:00 AM

Project: **BOE Pb Requirement Shaner Elementary - Initial**

Analytical Results

Client Sample Description S-9-WC / Room K18 Fountain **Collected:** 3/12/2022 8:05:00 AM **Lab ID:** 012204009-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:01

Client Sample Description S-11-BF / Hall Near Cafeteria Bottle Filler **Collected:** 3/12/2022 8:06:00 AM **Lab ID:** 012204009-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:03

Client Sample Description S-13-WC / Computer Laboratory Fountain **Collected:** 3/12/2022 8:07:00 AM **Lab ID:** 012204009-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:05

Client Sample Description S-14-WC / Room 102 Fountain **Collected:** 3/12/2022 8:08:00 AM **Lab ID:** 012204009-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.40	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:06

Client Sample Description S-15-WC / Room 101 Fountain **Collected:** 3/12/2022 8:09:00 AM **Lab ID:** 012204009-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.41	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:08

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012204009
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 3/14/2022 10:00 AM

Project: **BOE Pb Requirement Shaner Elementary - Initial**

Analytical Results

Client Sample Description S-16-WC / Room 105 Fountain **Collected:** 3/12/2022 8:10:00 AM **Lab ID:** 012204009-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:09

Client Sample Description S-17-SNK / Nurse Sink **Collected:** 3/12/2022 8:11:00 AM **Lab ID:** 012204009-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:17

Client Sample Description S-18-WC / Hall Near Room 106 R Fountain **Collected:** 3/12/2022 8:12:00 AM **Lab ID:** 012204009-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.67	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:19

Client Sample Description S-19-WC / Hall Near Room 106 L Fountain **Collected:** 3/12/2022 8:13:00 AM **Lab ID:** 012204009-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:20

Client Sample Description S-20-WC / Room 107 Fountain **Collected:** 3/12/2022 8:14:00 AM **Lab ID:** 012204009-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:22

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012204009
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 3/14/2022 10:00 AM

Project: **BOE Pb Requirement Shaner Elementary - Initial**

Analytical Results

Client Sample Description S-21-WC / Room 106 Fountain **Collected:** 3/12/2022 8:15:00 AM **Lab ID:** 012204009-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.24	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:23

Client Sample Description S-22-WC / Room 108 Fountain **Collected:** 3/12/2022 8:16:00 AM **Lab ID:** 012204009-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:25

Client Sample Description S-23-WC / Room 109 Fountain **Collected:** 3/12/2022 8:17:00 AM **Lab ID:** 012204009-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:26

Client Sample Description S-24-WC / Room 110 Fountain **Collected:** 3/12/2022 8:18:00 AM **Lab ID:** 012204009-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:28

Client Sample Description S-25-WC / Room 118 Fountain **Collected:** 3/12/2022 8:19:00 AM **Lab ID:** 012204009-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.61	1.00 µg/L	3/23/2022 JM	3/23/2022 JM 18:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012204009
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 3/14/2022 10:00 AM

Project: **BOE Pb Requirement Shaner Elementary - Initial**

Analytical Results

Client Sample Description S-26-WC / Room 111 Fountain **Collected:** 3/12/2022 8:20:00 AM **Lab ID:** 012204009-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:15

Client Sample Description S-27-WC / Room 116 Fountain **Collected:** 3/12/2022 8:21:00 AM **Lab ID:** 012204009-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.37	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:20

Client Sample Description S-28-WC / Library Fountain **Collected:** 3/12/2022 8:22:00 AM **Lab ID:** 012204009-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.01	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:21

Client Sample Description S-29-SNK / Room 115 Fountain **Collected:** 3/12/2022 8:23:00 AM **Lab ID:** 012204009-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.13	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:23

Client Sample Description S-30-SNK / Child Study Team (CST) Sink **Collected:** 3/12/2022 8:24:00 AM **Lab ID:** 012204009-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:24

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012204009
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 3/14/2022 10:00 AM

Project: **BOE Pb Requirement Shaner Elementary - Initial**

Analytical Results

Client Sample Description S-33-WC / Room 121 Fountain **Collected:** 3/12/2022 8:26:00 AM **Lab ID:** 012204009-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.92	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:26

Client Sample Description S-34-WC / Room 123 Fountain **Collected:** 3/12/2022 8:27:00 AM **Lab ID:** 012204009-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:27

Client Sample Description S-35-WC / Room 125 Fountain **Collected:** 3/12/2022 8:28:00 AM **Lab ID:** 012204009-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:32

Client Sample Description S-36-WC / Room 122 Fountain **Collected:** 3/12/2022 8:29:00 AM **Lab ID:** 012204009-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:34

Client Sample Description S-37-WC / Room 124 Fountain **Collected:** 3/12/2022 8:30:00 AM **Lab ID:** 012204009-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.81	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:35

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012204009
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 3/14/2022 10:00 AM

Project: **BOE Pb Requirement Shaner Elementary - Initial**

Analytical Results

Client Sample Description S-38-WC / Room 126 Fountain **Collected:** 3/12/2022 8:31:00 AM **Lab ID:** 012204009-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.68	1.00 µg/L	3/25/2022 JM	3/25/2022 JW 22:52

Client Sample Description S-39-WC / Room 127 Fountain **Collected:** 3/12/2022 8:32:00 AM **Lab ID:** 012204009-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/25/2022 JM	3/25/2022 JW 23:00

Client Sample Description S-40-WC / Room K10 Fountain **Collected:** 3/12/2022 8:33:00 AM **Lab ID:** 012204009-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/25/2022 JM	3/25/2022 JW 23:03

Client Sample Description S-41-WC / Room K7 Fountain **Collected:** 3/12/2022 8:34:00 AM **Lab ID:** 012204009-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/25/2022 JM	3/25/2022 JW 23:10

Client Sample Description S-42-WC / Room K6 Fountain **Collected:** 3/12/2022 8:35:00 AM **Lab ID:** 012204009-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/25/2022 JM	3/25/2022 JW 23:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012204009
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 3/14/2022 10:00 AM

Project: **BOE Pb Requirement Shaner Elementary - Initial**

Analytical Results

Client Sample Description S-43-WC / Room K5 Fountain **Collected:** 3/12/2022 8:36:00 AM **Lab ID:** 012204009-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/25/2022 JM	3/25/2022 JW 23:16

Client Sample Description S-44-WC / Room K11 Fountain **Collected:** 3/12/2022 8:37:00 AM **Lab ID:** 012204009-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/25/2022 JM	3/25/2022 JW 23:18

Client Sample Description S-45-WC / Room K4 Fountain **Collected:** 3/12/2022 8:38:00 AM **Lab ID:** 012204009-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/25/2022 JM	3/25/2022 JW 23:21

Client Sample Description S-46-WC / Room K13 Fountain **Collected:** 3/12/2022 8:39:00 AM **Lab ID:** 012204009-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/25/2022 JM	3/25/2022 JW 23:23

Client Sample Description S-47-WC / Room K12 Fountain **Collected:** 3/12/2022 8:40:00 AM **Lab ID:** 012204009-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/25/2022 JM	3/25/2022 JW 23:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012204009
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 3/14/2022 10:00 AM

Project: **BOE Pb Requirement Shaner Elementary - Initial**

Analytical Results

Client Sample Description S-48-WC / Room K3 Fountain **Collected:** 3/12/2022 8:41:00 AM **Lab ID:** 012204009-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:37

Client Sample Description S-49-WC / Room K1 Fountain **Collected:** 3/12/2022 8:42:00 AM **Lab ID:** 012204009-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:41

Client Sample Description S-50-WC / Room K2 Fountain **Collected:** 3/12/2022 8:43:00 AM **Lab ID:** 012204009-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:43

Client Sample Description S-51-WC / Faculty Room Fountain **Collected:** 3/12/2022 8:44:00 AM **Lab ID:** 012204009-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:44

Client Sample Description S-52-WC / Room K14 Fountain **Collected:** 3/12/2022 8:45:00 AM **Lab ID:** 012204009-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:46

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012204009
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 3/14/2022 10:00 AM

Project: **BOE Pb Requirement Shaner Elementary - Initial**

Analytical Results

Client Sample Description S-53-WC / Room K15 Fountain **Collected:** 3/12/2022 8:46:00 AM **Lab ID:** 012204009-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:51

Client Sample Description S-54-WC / Room K16 Fountain **Collected:** 3/12/2022 8:47:00 AM **Lab ID:** 012204009-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:52

Client Sample Description S-55-WC / Main Office Fountain **Collected:** 3/12/2022 8:48:00 AM **Lab ID:** 012204009-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:54

Client Sample Description Blank **Collected:** 3/12/2022 **Lab ID:** 012204009-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	3/28/2022 VD	3/28/2022 VD 22:55

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results